

Draft FPP Change Form

9/14/07

Change Request Number: 08TDA_008

Date:

10/29/2007

Proposed by: TDA Project Fisheries

Location of Change

TDA-19 3.2.2.1. add d.

Proposed Change:

To prepare a turbine for dewatering, the ice/trash sluiceway can be temporarily close to install a gatewell orifice plug.

Reason for Change:

Turbine units cannot be dewatered while the sluiceway is in operation with the gatewell orifices open. Unit dewaterings are required for maintenance.

Comments from others:

Record of Final Action: